

Date 7/21/26

Dear Capon Bridge Water Customers,

Capon Bridge Water Department appreciates your participation in the lead tap monitoring program. A lead level of 1ug/L or Parts Per Billion written as 0.001 mg/L on your results sheet was reported for the sample collected on 7/7/26 at your location, 146 Settlers Lane.

We are happy to report that your result, as well as the 90th percentile value for our water system, is below the lead action level of 15 parts per billion(ppb).

What Does This Mean?

Under the authority of the Safe Drinking Water Act, EPA set the action level for lead in drinking water at 15 ppb. This means utilities must ensure that water from the customer's tap does not exceed this level in at least 90 percent of the homes sampled (90th percentile value). The action level is *the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow*. If water from the tap does exceed the limit, then the utility must take certain steps to correct the problem. Because lead may pose serious health risks, the EPA set a Maximum Contaminant Level Goal (MCLG) of zero for lead. The MCLG is *the level of a contaminant in drinking water below which there is no known or expected risk to health*. MCLGs allow for a margin of safety.

What Are the Health Effects of Lead?

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

What Are the Sources of Lead?

The primary sources of lead exposure for most children are deteriorating lead-based paint, lead-contaminated dust, and lead-contaminated residential soil. Exposure to lead is a significant health concern, especially for young children and infants whose growing bodies tend to absorb more lead than the average adult. Although your home's drinking water lead levels were below the action level, if you are concerned about lead exposure, parents should ask their health care providers about testing children for high levels of lead in the blood.

What Can I Do to Reduce Exposure to Lead in Drinking Water?

- **Run your water to flush out lead.** If water has not been used for several hours, run water for 15 – 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking. This flushes lead-containing water from the pipes.
- **Use cold water for cooking and preparing baby formula.** Do not cook with or drink water from the hot water tap; lead dissolves more easily into hot water. Do not use water from the hot water tap to make baby formula.
- **Do not boil water to remove lead.** Boiling water will not reduce lead.
- **Look for alternative sources or treatment of water.** You may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010 or www.nsf.org for information on performance standards for water filters.
- **Test your water for lead.** Call us at 304-856-3625 to find out how to get your water tested for lead. The Town of Capon Bridge completes all testing that the WVDHHR requires. If you would like any additional sampling or testing at your expense, Please contact any WV state certified labs on the WVDHHR website or contact the Capon Bridge Water Department at the above number or email publicworks@townofcaponbridgewv.gov
- **Identify if your plumbing fixtures contain lead.** New brass faucets, fittings, and valves, including those advertised as “lead-free,” may contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, with up to 8 percent lead to be labeled as “lead-free.” Consumers should be aware of this when choosing fixtures and take appropriate precautions.

For More Information

Call us at Capon Bridge water Department (304) 856-3625 or email publicworks@townofcaponbridgewv.gov or stop by the Town Hall at 259 Whitacre Lane Capon Bridge WV 26711. For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

3020 VENTRIE COURT
MYERSVILLE, MD 21773



(301) 293-3340
INFO@FTLLAB.COM

Client: Town of Capon Bridge INC
259 Whitacre Loop
Capon Bridge, WV 26711

Project: Capon Bridge 3301402 - Pb & Cu

July 2026 ① LCO12 1 ppb - vs/L

Site: N/A

② LCO16 1
③ LCO22 1
④ LCO25 1
⑤ LCO26 1
⑥ LCO27 1
⑦ LCO28 1
⑧ LCO17 2
⑨ LCO29 5 ppb 90th percentile
⑩ LCO19 9

Work order: FAG0317

Received at lab: 07/08/26 12:32
Date Reported: 07/17/26 07:37
Collected by: Chris Turner
Treatment: N/A

Source: 146 Settlers Lane LCO12
(Drinking Water)(Grab)

Regulatory ID: 3301402
Collected: 07/07/26 17:00

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0317-01	Copper, First Draw	0.381	mg/L	0.001	0.00006	1	07/15/26 15:50	07/15/26 15:50	NM		200.8
FAG0317-01	Lead, First Draw	<0.001	mg/L	0.001	0.00005	1	07/15/26 15:50	07/15/26 15:50	NM		200.8

1 ppb vs/L

Source: 69 Settlers Lane LCO16
(Drinking Water)(Grab)

Collected: 07/08/26 05:10

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0317-02	Copper, First Draw	0.580	mg/L	0.001	0.00006	1	07/15/26 15:53	07/15/26 15:53	NM		200.8
FAG0317-02	Lead, First Draw	<0.001	mg/L	0.001	0.00005	1	07/15/26 15:53	07/15/26 15:53	NM		200.8

1 ppb vs/L

Source: 48 One Mile Lane LCO17
(Drinking Water)(Grab)

Collected: 07/07/26 23:30

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0317-03	Copper, First Draw	0.318	mg/L	0.001	0.00006	1	07/15/26 15:56	07/15/26 15:56	NM		200.8
FAG0317-03	Lead, First Draw	0.002	mg/L	0.001	0.00005	1	07/15/26 15:56	07/15/26 15:56	NM		200.8

2 ppb vs/L

Source: 125 Clark Hillside Drive LCO19
(Drinking Water)(Grab)

Collected: 07/07/26 16:30

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0317-04	Copper, First Draw	0.502	mg/L	0.001	0.00006	1	07/15/26 15:59	07/15/26 15:59	NM		200.8
FAG0317-04	Lead, First Draw	0.009	mg/L	0.001	0.00005	1	07/15/26 15:59	07/15/26 15:59	NM		200.8

9 ppb vs/L

Sara E. Randall
Sara E. Randall, President

Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
Maryland Cert. No. 116 Virginia Cert. No. 00444
West Virginia Cert. 415 MDOT WBE Cert. No.: 91-158

3020 VENTRIE COURT
MYERSVILLE, MD 21773



(301) 293-3340
INFO@FTLLAB.COM

Client: Town of Capon Bridge INC
259 Whitacre Loop
Capon Bridge, WV 26711

Project: Capon Bridge 3301402 - Pb & Cu
July 2026

Site: N/A

Work order: FAG0317

Received at lab: 07/08/26 12:32
Date Reported: 07/17/26 07:37
Collected by: Chris Turner
Treatment: N/A

Source: 215 Christian Church Road LC022
(Drinking Water)(Grab)

Collected: 07/07/26 19:24

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0317-05	Copper, First Draw	0.033	mg/L	0.001	0.00006	1	07/15/26 16:01	07/15/26 16:01	NM		200.8
FAG0317-05	Lead, First Draw	<0.001	mg/L	0.001	0.00005	1	07/15/26 16:01	07/15/26 16:01	NM		200.8

1 ppb vs/L

Notes and Definitions

Item Definition

Sara E. Randall
Sara E. Randall, President

Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
Maryland Cert. No. 116 Virginia Cert. No. 00444
West Virginia Cert. 415 MDOT WBE Cert. No.: 91-158

3020 VENTRIE COURT
MYERSVILLE, MD 21773



(301) 293-3340
INFO@FTLLAB.COM

Client: Town of Capon Bridge INC
259 Whitacre Loop
Capon Bridge, WV 26711

Project: Capon Bridge 3301402 - Pb & Cu
July 2026
Site: N/A

Work order: FAG0316

Received at lab: 07/08/26 12:32
Date Reported: 07/17/26 07:35
Collected by: Chris Turner
Treatment: N/A

Source: 204 Settlers Lane LC025
(Drinking Water)(Grab)

Regulatory ID: 3301402
Collected: 07/07/26 20:00

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0316-01	Copper, First Draw	0.131	mg/L	0.001	0.00006	1	07/15/26 15:26	07/15/26 15:26	NM		200.8
FAG0316-01	Lead, First Draw	<0.001	mg/L	0.001	0.00005	1	07/15/26 15:26	07/15/26 15:26	NM		200.8

1 ppb ug/L

Source: 176 Clark Hillside Drive LC026
(Drinking Water)(Grab)

Collected: 07/08/26 07:00

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0316-02	Copper, First Draw	0.050	mg/L	0.001	0.00006	1	07/15/26 15:32	07/15/26 15:32	NM		200.8
FAG0316-02	Lead, First Draw	<0.001	mg/L	0.001	0.00005	1	07/15/26 15:32	07/15/26 15:32	NM		200.8

1 ppb ug/L

Source: 167 Clark Hillside Drive LC027
(Drinking Water)(Grab)

Collected: 07/08/26 06:30

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0316-03	Copper, First Draw	0.060	mg/L	0.001	0.00006	1	07/15/26 15:35	07/15/26 15:35	NM		200.8
FAG0316-03	Lead, First Draw	<0.001	mg/L	0.001	0.00005	1	07/15/26 15:35	07/15/26 15:35	NM		200.8

1 ppb ug/L

Source: 925 Christian Church Road LC028
(Drinking Water)(Grab)

Collected: 07/08/26 07:30

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0316-04	Copper, First Draw	0.010	mg/L	0.001	0.00006	1	07/15/26 15:38	07/15/26 15:38	NM		200.8
FAG0316-04	Lead, First Draw	<0.001	mg/L	0.001	0.00005	1	07/15/26 15:38	07/15/26 15:38	NM		200.8

1 ppb ug/L

Sara E. Randall
Sara E. Randall, President

Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
Maryland Cert. No. 116 Virginia Cert. No. 00444
West Virginia Cert. 415 MDOT WBE Cert. No.: 91-158

3020 VENTRIE COURT
MYERSVILLE, MD 21773



(301) 293-3340
INFO@FTLLAB.COM

Client: Town of Capon Bridge INC
259 Whitacre Loop
Capon Bridge, WV 26711

Project: Capon Bridge 3301402 - Pb & Cu
July 2026

Site: N/A

Work order: FAG0316

Received at lab: 07/08/26 12:32
Date Reported: 07/17/26 07:35
Collected by: Chris Turner
Treatment: N/A

Source: 338 Settlers Lane Lco29
(Drinking Water)(Grab)

Collected: 07/08/26 08:00

Data Analyzed by: Fredericktowne Labs:

Lab ID	Parameter	Result	Units	MRL	MDL	DF	Prepared	Analyzed	Analyst	Qual	Method
FAG0316-05	Copper, First Draw	0.125	mg/L	0.001	0.00006	1	07/15/26 15:41	07/15/26 15:41	NM		200.8
FAG0316-05	Lead, First Draw	0.005	mg/L	0.001	0.00005	1	07/15/26 15:41	07/15/26 15:41	NM		200.8

5 ppb ug/L

Notes and Definitions

Item **Definition**

Sara E. Randall
Sara E. Randall, President

Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
Maryland Cert. No. 116 Virginia Cert. No. 00444
West Virginia Cert. 415 MDOT WBE Cert. No.: 91-158



FREDERICKTOWNE LABS ENVIRONMENTAL TESTING 3020 VENTURE COURT, SUITE A, WYOMING, MD 21773

CLIENT

Town of Capon Bridge # 3301402

301-293-3340 | INFO@FTILAB.COM | FTILAB.COM
PHONE 540-533-1556 mobile
304-856-3625 Office

PROJECT / ADDRESS

Town of Capon Bridge Lead & Copper

EMAIL

publicworks@townofcaponbridgeva.gov

COLLECTED BY

Chris Turner

AFFILIATION

Town of Capon Bridge

☐ MD ☐ VA
☒ WV ☐ Other

☐ REGULATED
3301402

Regulatory ID #

WORK ORDER #

FA60317

TEMPERATURE

2

UPON RECEIPT (C)

ATTEMPT MADE TO COOL?


☒ YES

☐ NO

Thermometer #

74

ANALYSES TO BE PERFORMED



☐ RUSH
☐ Requested By Date/Time
☒ FIRST DRAW
☐ Date/Time Water Test Used

TREATMENT DEVICES
☐ Acid Neutralizer ☐ UV Light
☐ Chlorinator ☐ Treatment Offline
☐ Filter ☐ Water Softener
☐ Municipal Water ☐ None
☐ RO System ☐ Other

FIELD SAMPLE ID	SITE DESCRIPTION	Last Used		Collected		MATRIX	GRAB/COMP	pH	RES. CL.	DO	TEMP (°F/°C)	CONTAINER PRESERVATIVE/MATERIAL	TOTAL NUMBER OF CONTAINERS
		DATE	TIME	DATE	TIME								
LC012	146 Settlers Lane	7/7/26	7:30 PM	7/7/26	5:00 PM	DW	G					8.0	1
LC016	69 Settlers Lane	7/7/26	9:00 PM	7/8/26	5:10 PM	DW	G					3.0	1
LC017	48 One Mile Lane	7/7/26	5:30 PM	7/7/26	11:30 PM	DW	G						
LC019	125 Clark Hillside Drive	7/7/26	6:00 PM	7/7/26	4:30 PM	DW	G						
LC022	215 Christian Church Road	7/7/26	8:00 PM	7/7/26	7:24 PM	DW	G						

RECEIVED BY
Signature: *Nicola Daily*
Date/Time: 7/8/26

RECEIVED BY
Signature: *Nicola Daily*
Date/Time: 7/8/26

Signature: _____
Date/Time: _____

Signature: _____
Date/Time: _____

Signature: _____
Date/Time: _____

Signature: _____
Date/Time: _____

NOTES
Please include field pH, temperature and Res. CL2 m/L on all samples to the report.
Due to customer sampling there is no pH or CL2 Res. to report, only Lab receipt temp.



FEDERICKTOWNE LABS ENVIRONMENTAL TESTING 3020 VENTRIE COURT, SUITE A, MYERSVILLE, MD 21773

301-293-3340 | INFO@FTLLAB.COM | FTLLAB.COM

CLIENT
Town of Capon Bridge # 3301402

PHONE
304-856-3625 Office

PROJECT /
ADDRESS
Town of Capon Bridge Lead & Copper

EMAIL
publicworks@townofcaponbridgeva.gov

COLLECTED BY
Chris Turner

AFFILIATION
Town of Capon Bridge


☐ MD ☐ VA
☒ WV ☐ Other
REGULATED
3301402
Regulatory ID #

WORK ORDER #

FA60316

TEMPERATURE .5 THERMOMETER 44
UPON RECEIPT (C)
ATTEMPT MADE TO COOL? YES NO

ANALYSES TO BE PERFORMED



☐ RUSH
☐ Requested By Date/Time
☒ FIRST DRAW
Date/Time Water Last Used
TREATMENT DEVICES
☐ Acid Neutralizer ☐ UV Light
☐ Chlorinator ☐ Treatment Offline
☐ Filter ☐ Water Softener
☐ Municipal Water ☐ None
☐ RO system ☐ Other

FIELD SAMPLE ID	SITE DESCRIPTION	Last Used		Collected		MATRIX	GRAB/ COMP	pH	RES. CL	DO	TEMP (F/C)	CONTAINER PRESERVATIVE/MATERIAL	TOTAL NUMBER OF CONTAINERS
		DATE	TIME	DATE	TIME								
LC025	204 Settlers Lane	7/1/26	7:00 Am	7/7/26	8:00 Am	DW	G					8.0	1
LC026	176 Clark Hillside Drive	7/1/26	6:30 Am	7/8/26	7:00 Am	DW	G					3.0	1
LC027	167 Clark Hillside Drive	7/1/26	11:45 Am	7/8/26	6:30 Am	DW	G						
LC028	925 Christian Church Road	7/1/26	11:30 Am	7/8/26	7:30 Am	DW	G						
LC029	338 Settlers Lane	7/7/26	2:00 Pm	7/8/26	8:00 Am	DW	G						

REINQUISHED
Signature *Chris Turner* Date/Time 7/8/26 1238

RECEIVED BY
Signature *Nicole Daryl* Date/Time 7.8.26 1238

REINQUISHED
Signature _____ Date/Time _____

RECEIVED BY
Signature _____ Date/Time _____

Signature _____ Date/Time _____

Signature _____ Date/Time _____

NOTES
Please include field pH, temperature and Res. CL2 mg/L on all samples on the report.

Due to customer sampling there is no pH or CL2 Res. to report, only Lab receipt temp.